

2430 "E" Street, N. W.
Washington, D. C.
4 March 1954

25X1A9a




Subject: Exhaust System for
Toilet Rooms

25X1A9a

Dear 

Your letter of 25 February 1954, concerning reference matter has been received and contents noted.

25X1A9a

After discussion of the matter with  it would appear that the likelihood of trouble is quite remote, since prevailing temperatures as well as minimum temperatures on record indicate that condensation will rarely, if ever, occur. *

I believe, however, that the point is well taken, and that it would be advisable to leave with the users some record of this discussion in order to avoid their reaching the erroneous conclusion mentioned in the first paragraph of your letter.

Very truly yours,

25X1A9a



** P.S. Lowest recorded temperature 29°, with
no freezing temp. recorded in past 10 years.*